



WE SERVE TO SAVE

DEPARTMENT OF FIRE AND RESCUE SERVICES
GOVERNMENT OF KERALA

No: FRS/VKCY/4576/2025/RENEWAL

Date:26-6-2025

RENEWAL CERTIFICATE

NAME & ADDRESS OF THE APPLICANT	: MANAGER ST XAVIERS CENTRAL SCHOOL, MANGALAMDAM,MANGALAMDAM,PALAKKAD,PALAKKAD- 678706
NAME OF THE COMPANY	: ST XAVIERS CENTRAL SCHOOL
OCCUPANCY TYPE	: EDUCATIONAL BUILDING
HEIGHT OF THE BUILDING	: 13.74 Metre
NO OF FLOOR	: 4
PLINTH AREA	: 1599.17 m ²
FINAL NOC NO. AND DATE OF ISSUE AND ISSUED BY	: FRS09/VKCY/15957/2023 dated 2023-06-08 Issued by REGIONAL FIRE OFFICER PALAKKAD
SURVEY NO	: 33J
VILLAGE	: MANGALAMDAM
PANCHAYAT	: VANDAZHY
DISTRICT	: PALAKKAD

1. The Board headed by the Station Officer, Fire and Rescue station, VADAKKANCHERY(PKD) has inspected the above said building and recommended to renew the No objection Certificate.

2. In the circumstances, this No Objection Certificate is issued under my authority for the continued occupation of the above building. No further construction will be allowed in the vacant spaces provided in the approved plan.

3. This certificate is issued on the condition that the fire fighting system installed will be kept always functional and the owner of the building should take special care to maintain the systems installed in proper working condition. **This certificate is valid for one year from the date of issue. After one year the certificate must be renewed. Non renewal of the certificate within the time limit will result in the loss of eligibility for insurance coverage and appropriate legal action by the Local Self Government/Revenue Department.** All Officers of and above the rank of Station Officers of the Fire & Rescue Services Department will have the right to inspect the building on any day/time after serving 7 days notice to ensure that the installed systems are in good working condition.



Certificate issued by PRAGOSH K T
Station Officer : VADAKKANCHERY(PKD)
Date of Issue 2025-06-26 13:23:46

To,
Applicant / Concerned Local Authority

** This is a Computer Generated Certificate & signature is not required.*

No: 175/25

SANITARY CERTIFICATE

This is to certify that Sri/Smt Principal St. Xaviers Central School -
Has provided necessary arrangements for running a St. Xaviers central school -
Building No. 12/655/A.
Mangelem dam.

This certificate is valid for one year from 21.6.2025 to 31.03.2026.
during this period if the Sanitary Condition is not satisfactory in inspection the certificate will be
cancelled.

This certificate is issued for obtaining license (D & O) from Grama Panchayath,
Vandazhi.

Place : vandazhi
Date : 21.6.2025



[Signature]
Health Inspector / Health Officer
Family Health
Vandazhi, Palakkad

TO BE FILLED BY THE INSPECTING OFFICER

(Assistant Engineer)

SFS/AR VDY/14/2025-26, Dt: 26/6/25

- Name of School : St.Xavier's Central School, Mangalam dam
- 1 Name of Officer : Haridas R, Assistant Engineer,
LSGD Section, Vandazhy Grama Panchayath
- 2 Location : Mangalam Dam
- 3 Period which the certificate is issued 2025-26
- 4 Type of Building : RCC Building
- 5 Nature of defect if any :

a) Foundation and Basemer	:	Nil
b) Super Structure	:	
c) Doors and Windows	:	
d) Wood work Wrought & put up	:	
e) Roof	:	
f) Flooring	:	
g) Miscellaneous	:	
- Cellar floor - 24.55m x13.66m x3.60m
Ground floe - 49.48m x10.20m x3.60m
First floor - 49.48m x10.20m x3.60m
- 6 Any Major defects noticed which will render the building unsafe in any manner : No
- 7 Whether maintenance work have been done : Yes
- 8 Weather the structure is sound for conducting classes : The Structure is sound for conduct classes under normal weather condition.

Note (1) The stability of the structure should be examined also with reference to location, altitude, intensity of wind, exposure to flood etc.

(2) Any additional observations, if deemed necessary for the certificate may be furnished separately with the certificate.

Certified that the school was inspected by me on 25/06/2025 and found fit to conduct classes for the period 2025-26 for the reasons stated above.

Place: Vandazhy
Date : 26/6/2025

Signature



[Handwritten Signature]
HARIDAS R
PEN : 370153
ASSISTANT ENGINEER
LID & EW SECTION
VANDAZHY GRAMA PANCHAYATH
678 709

SCHOOL PROTECTION GROUP MEMBERS

2025-26

NAME OF POLICE STATION:-MANGALAMDAM

SINo	Particulars	Name	PhoneNo	Remar
1	School/ College	School St.Xavier's Central School,Mangalamdam	9846137834	
2	Chairman (HM/Principal/)	Fr.Sibin Thomas (Principal)	9847578405	
3	NameofVice Chair,man (SeniorAsst/Vice.Principal)	Jancy T M	6282651892	
4	Convener(SHO)			
5	JointConvener(PoliceofficerDesignatedbySHO)			
6	Member-1(Ward Member/Cquncillor)	Molly Sunny	9605772825	
7	Member-2(PTAPresident)	Ajithkumar	9207653632	
8	Member-3(MPTAPresident)	Shibi Thomas	9895706078 9447317096	
9	Member-4(SchoolManagementCommitteeChairman)	Fr. Mathew George Vazhayil	9447534016	
10	Member-5(Staffsecretary)	Sinderla M K	8590529499	
11	Member-6(RepresntativefromTeacher)	Hemalatha C	9605543758	
12	Member-7(RepresntativefromTeacher)	Sali M T	9048928544	
13	Member-8(SchoolLeader-Boy)	Benedict Joseph	8590971226	
14	Member-9(SchoolLeader-Girl)	Helen Mary Mathew	9961564076	
15	Member-10(SchoolCouncilor)	Stella Wellness	9074687099	
16	Member-11(MerchantRepresentative)			
17	Member-12(RepresentativfromAutorikshaDrivers)			
18	Member-13(OnememberfromPanchayathjagratha Samithi)			
19	Member-14(OnememberfromSPC/NCC/Coutand Guid/JRC)			
20	Member-15(ExciseDept)			
21	Member-16(MVDDept)			
22	Member-17(FIREandRescue)			
23	Member-18(ResidenceAssociation-)			

TEST REPORT

REPORT NO : EMAL/WA 4278/2025

REPORT DATE : 12-06-2025

M/S. St.Xavier's Central School
Mangalam Dam
Palakkad

SAMPLE REFERENCE ID : WA 4278

SAMPLE RECEIPT DATE : 09-06-2025

PERIOD OF ANALYSIS : 09-06-2025 to 12-06-2025

SAMPLE DRAWN BY : Customer

SAMPLE SOURCE : Open Well

I. TEST RESULTS

Sl. No	Parameter	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	pH	-	APHA 2023-4500H ⁺ B	6.5-8.5	6.5
2	Colour	CU	APHA 2023-2120B	5	BDL
3	Odor	-	IS:3025 (part5)	Agreeable	Agreeable
4	Turbidity	NTU	APHA 2023-2130B	1	BDL
5	Conductivity	µS/cm	APHA 2023- 2510B	-	40
6	Total Dissolved Solids	mg/L	APHA 2023-2540C	500	22
7	Total Hardness as CaCO ₃	mg/L	APHA 2023- 2340C	200	8
8	Total Alkalinity as CaCO ₃	mg/L	APHA 2023- 2320B	200	8
9	Calcium	mg/L	APHA 2023-3500-Ca B	75	BDL
10	Magnesium	mg/L	APHA 2023- 3500-Mg-B	30	2
11	Chloride	mg/L	APHA 2023-4500 Cl ⁻ B	250	8
12	Nitrate - NO ₃	mg/L	APHA 2023- 4500 NO ₃ ⁻ B	45	0.8
13	Iron	mg/L	APHA 2023- 3500-Fe B	1	0.01
14	Sulphate	mg/L	APHA 2023-4500-SO ₄ ²⁻	200	BDL
15	Ammoniacal Nitrogen	mg/L	APHA 2023-4500NH ₃ F	0.5	BDL
16	Total Coliform	CFU/100mL	APHA 2023-9222B	Shall not be detectable in any 100 ml sample	Absent
17	Faecal Coliform	CFU/100mL	APHA 2023- 9222D	Shall not be detectable in any 100 ml sample	Absent

BDL:Below Detection Limit

Inferences: All the tested water quality parameters are within the acceptable limit as per IS10500-2012 drinking water specifications.

Sonyam
Analyst



P. Indhujale
Authorized Signatory

Disclaimer: a) The Test results listed refer only to the tested samples and application parameters. b) Total Liability of the lab is to invoiced amount only. c) The test report refers to the sample submitted to the lab and not drawn by EMAL unless mentioned otherwise. d) The test report is not to be reproduced wholly or in part without written permission of the laboratory.